

Beräkning av blandning enligt UGR

p Tak	70	70	50	50	30	70	70	50	50	30	
p Vägg	50	30	50	30	30	50	30	50	30	30	
p Golv	20	20	20	20	20	20	20	20	20	20	
Rumsstorlek X	Y	Blickriktning tvärs till tvärsaxel						Blickriktning längs till tvärsaxel			
2H	2H	17.7	18.9	18.1	19.2	19.6	17.5	18.7	17.9	19.0	19.4
2H	3H	19.1	20.1	19.5	20.5	21.0	18.6	19.6	19.1	20.0	20.5
2H	4H	19.8	20.8	20.3	21.2	21.7	19.2	20.1	19.6	20.6	21.0
2H	6H	20.6	21.5	21.1	22.0	22.4	19.7	20.6	20.2	21.1	21.6
2H	8H	21.1	22.0	21.6	22.4	22.9	20.1	20.9	20.6	21.4	21.9
2H	12H	21.7	22.5	22.2	23.0	23.5	20.4	21.3	20.9	21.7	22.2
4H	2H	18.1	19.1	18.6	19.5	20.0	18.0	18.9	18.4	19.4	19.8
4H	3H	19.7	20.5	20.2	21.0	21.5	19.3	20.1	19.8	20.6	21.1
4H	4H	20.6	21.3	21.1	21.8	22.4	20.0	20.7	20.5	21.2	21.8
4H	6H	21.6	22.3	22.2	22.8	23.4	20.8	21.4	21.3	21.9	22.5
4H	8H	22.3	22.8	22.8	23.4	24.0	21.2	21.8	21.8	22.3	22.9
4H	12H	23.0	23.5	23.6	24.1	24.7	21.7	22.2	22.2	22.8	23.4
8H	4H	20.9	21.5	21.4	22.0	22.6	20.3	20.9	20.9	21.5	22.1
8H	6H	22.1	22.6	22.7	23.2	23.8	21.3	21.8	21.9	22.4	23.0
8H	8H	22.9	23.3	23.5	23.9	24.6	21.9	22.3	22.5	22.9	23.6
8H	12H	23.9	24.2	24.5	24.9	25.5	22.5	22.9	23.2	23.5	24.2
12H	4H	20.9	21.5	21.5	22.0	22.6	20.4	20.9	21.0	21.5	22.1
12H	6H	22.2	22.7	22.9	23.3	23.9	21.5	21.9	22.1	22.5	23.2
12H	8H	23.1	23.5	23.7	24.1	24.8	22.1	22.5	22.8	23.1	23.8

Variation av öskåderposition för bäravstånd S

S = 1.0H	+0.2 / -0.1	+0.2 / -0.2
S = 1.5H	+0.2 / -0.4	+0.3 / -0.5
S = 2.0H	+0.3 / -0.6	+0.5 / -0.8

Standardtabell	BK08	BK06
Korrektionsfaktor	6.6	4.9

Konjugerade blandindikeringar relaterade till total ljusflöde