

Beräkning av blandning enligt UGR

p Tak	70	70	50	50	30	70	70	50	50	30	
p Vägg	50	30	50	30	30	50	30	50	30	30	
p Golv	20	20	20	20	20	20	20	20	20	20	
Rumsstorlek X	Y	Blickriktning tvärs till tvärsaxel					Blickriktning längs till tvärsaxel				
2H	2H	23.4	24.5	23.7	24.7	25.0	31.1	32.2	31.4	32.5	32.8
2H	3H	23.2	24.2	23.6	24.5	24.8	32.5	33.5	32.8	33.7	34.0
2H	4H	23.2	24.1	23.5	24.4	24.7	32.7	33.7	33.1	34.0	34.3
2H	6H	23.1	24.0	23.5	24.3	24.6	32.7	33.6	33.1	33.9	34.2
2H	8H	23.1	23.9	23.5	24.3	24.6	32.7	33.5	33.1	33.8	34.2
2H	12H	23.1	23.9	23.5	24.2	24.6	32.6	33.4	33.0	33.8	34.1
4H	2H	24.3	25.2	24.7	25.5	25.8	31.0	32.0	31.4	32.3	32.6
4H	3H	24.2	25.0	24.6	25.3	25.7	32.4	33.2	32.8	33.6	33.9
4H	4H	24.1	24.8	24.5	25.2	25.6	32.7	33.4	33.2	33.8	34.2
4H	6H	24.1	24.7	24.5	25.1	25.5	32.7	33.3	33.2	33.7	34.2
4H	8H	24.1	24.6	24.5	25.0	25.5	32.7	33.2	33.2	33.7	34.1
4H	12H	24.1	24.5	24.5	25.0	25.4	32.7	33.2	33.2	33.6	34.1
8H	4H	24.3	24.8	24.8	25.3	25.7	32.6	33.2	33.1	33.6	34.0
8H	6H	24.3	24.7	24.8	25.2	25.6	32.6	33.1	33.1	33.5	34.0
8H	8H	24.3	24.6	24.8	25.1	25.6	32.6	33.0	33.1	33.5	34.0
8H	12H	24.3	24.6	24.8	25.1	25.6	32.6	32.9	33.1	33.4	33.9
12H	4H	24.3	24.8	24.8	25.2	25.7	32.6	33.1	33.1	33.5	34.0
12H	6H	24.3	24.6	24.8	25.1	25.6	32.6	33.0	33.1	33.4	34.0
12H	8H	24.2	24.6	24.8	25.1	25.6	32.6	32.9	33.1	33.4	33.9

Variation av öskåderposition för bäravstånd S

S = 1.0H	+1.9 / -4.2	+0.2 / -0.4
S = 1.5H	+3.3 / -9.3	+1.1 / -1.1
S = 2.0H	+4.9 / -10.2	+2.6 / -3.0

Standardtabell	BK01	BK03
Korrektionsfaktor	6.1	15.5

Konjugerade blandindikeringar relaterade till total ljusflöde