

Beräkning av bländning enligt UGR

| p Tak | 70 | 70 | 50 | 50 | 30 | 70 | 70 | 50 | 50 | 30 | |
|--|-----|------------------------------------|------|------|------|------|------------------------------------|------|------|------|------|
| p Vägg | 50 | 30 | 50 | 30 | 30 | 50 | 30 | 50 | 30 | 30 | |
| p Golv | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | |
| Rumsstorlek X Y | | Blickriktning tvärs till tvärsaxel | | | | | Blickriktning längs till tvärsaxel | | | | |
| 2H | 2H | 24.4 | 25.5 | 24.7 | 25.8 | 26.1 | 31.5 | 32.7 | 31.8 | 33.0 | 33.2 |
| 2H | 3H | 24.9 | 25.9 | 25.2 | 26.2 | 26.5 | 33.1 | 34.2 | 33.5 | 34.5 | 34.8 |
| 2H | 4H | 25.1 | 26.1 | 25.5 | 26.4 | 26.8 | 33.7 | 34.7 | 34.0 | 35.0 | 35.3 |
| 2H | 6H | 25.4 | 26.3 | 25.8 | 26.6 | 27.0 | 33.7 | 34.6 | 34.1 | 35.0 | 35.3 |
| 2H | 8H | 25.5 | 26.3 | 25.9 | 26.7 | 27.0 | 33.7 | 34.6 | 34.1 | 34.9 | 35.3 |
| 2H | 12H | 25.6 | 26.4 | 26.0 | 26.7 | 27.1 | 33.7 | 34.5 | 34.1 | 34.9 | 35.3 |
| 4H | 2H | 25.6 | 26.6 | 25.9 | 26.9 | 27.2 | 31.5 | 32.5 | 31.8 | 32.8 | 33.1 |
| 4H | 3H | 26.1 | 26.9 | 26.5 | 27.3 | 27.7 | 33.2 | 34.0 | 33.6 | 34.4 | 34.7 |
| 4H | 4H | 26.5 | 27.2 | 26.9 | 27.6 | 28.0 | 33.8 | 34.6 | 34.3 | 35.0 | 35.4 |
| 4H | 6H | 26.8 | 27.4 | 27.2 | 27.8 | 28.3 | 33.9 | 34.6 | 34.4 | 35.0 | 35.4 |
| 4H | 8H | 26.9 | 27.5 | 27.4 | 27.9 | 28.4 | 33.9 | 34.5 | 34.4 | 34.9 | 35.4 |
| 4H | 12H | 27.1 | 27.6 | 27.6 | 28.0 | 28.5 | 34.0 | 34.5 | 34.4 | 34.9 | 35.4 |
| 8H | 4H | 26.8 | 27.4 | 27.3 | 27.8 | 28.3 | 33.8 | 34.3 | 34.2 | 34.8 | 35.2 |
| 8H | 6H | 27.3 | 27.7 | 27.8 | 28.2 | 28.7 | 33.9 | 34.4 | 34.4 | 34.8 | 35.3 |
| 8H | 8H | 27.5 | 27.9 | 28.0 | 28.4 | 28.9 | 33.9 | 34.3 | 34.4 | 34.8 | 35.3 |
| 8H | 12H | 27.8 | 28.2 | 28.3 | 28.7 | 29.2 | 34.0 | 34.3 | 34.5 | 34.8 | 35.4 |
| 12H | 4H | 26.8 | 27.4 | 27.3 | 27.8 | 28.3 | 33.7 | 34.3 | 34.2 | 34.7 | 35.2 |
| 12H | 6H | 27.3 | 27.8 | 27.8 | 28.2 | 28.8 | 33.9 | 34.3 | 34.4 | 34.8 | 35.3 |
| 12H | 8H | 27.6 | 28.0 | 28.2 | 28.5 | 29.0 | 33.9 | 34.2 | 34.4 | 34.7 | 35.3 |
| Variation av åskådarposition för tvärsaxel S | | | | | | | | | | | |
| S = 1.0H | | +0.6 / -1.1 | | | | | +0.1 / -0.2 | | | | |
| S = 1.5H | | +1.4 / -1.8 | | | | | +0.6 / -0.7 | | | | |
| S = 2.0H | | +2.2 / -2.3 | | | | | +1.8 / -1.6 | | | | |
| Standardtabell Korrektionsfaktor | | BK04 9.9 | | | | | BK04 16.9 | | | | |
| Korrigerade bländindikeringar relaterade till totalt ljusflöde | | | | | | | | | | | |