

Beräkning av blandning enligt UGR

| ρ Tak | | 60 | 70 | 70 | 50 | 50 | 60 | 70 | 70 | 50 | 50 |
|------------------|-----|------------------------------------|------|------|------|------|------------------------------------|------|------|------|------|
| ρ Vågg | | 60 | 50 | 30 | 50 | 30 | 60 | 50 | 30 | 50 | 30 |
| ρ Golv | | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 |
| Rumsstorlek X | Y | Blickriktning tvärs till tvärsaxel | | | | | Blickriktning längs till tvärsaxel | | | | |
| 2H | 2H | 18.1 | 19.7 | 21.0 | 20.1 | 21.4 | 18.1 | 19.7 | 21.1 | 20.1 | 21.4 |
| 2H | 3H | 20.1 | 21.9 | 23.2 | 22.4 | 23.8 | 20.3 | 22.0 | 23.2 | 22.4 | 23.6 |
| 2H | 4H | 21.5 | 23.1 | 24.3 | 23.6 | 24.7 | 21.5 | 23.2 | 24.3 | 23.6 | 24.8 |
| 2H | 6H | 22.7 | 24.4 | 25.5 | 24.9 | 25.9 | 22.8 | 24.4 | 25.5 | 24.9 | 26.0 |
| 2H | 8H | 23.4 | 25.1 | 26.1 | 25.6 | 26.6 | 23.5 | 25.1 | 26.2 | 25.6 | 26.7 |
| 2H | 12H | 24.2 | 25.9 | 26.9 | 26.4 | 27.3 | 24.2 | 25.9 | 26.9 | 26.4 | 27.4 |
| 4H | 2H | 18.9 | 20.5 | 21.7 | 21.0 | 22.1 | 18.9 | 20.6 | 21.7 | 21.0 | 22.2 |
| 4H | 3H | 21.2 | 23.0 | 24.0 | 23.5 | 24.5 | 21.4 | 23.0 | 24.0 | 23.5 | 24.5 |
| 4H | 4H | 22.7 | 24.4 | 25.3 | 24.9 | 25.8 | 22.7 | 24.4 | 25.3 | 24.9 | 25.8 |
| 4H | 6H | 24.1 | 25.8 | 26.6 | 26.4 | 27.2 | 24.2 | 25.9 | 26.7 | 26.4 | 27.2 |
| 4H | 8H | 24.9 | 26.6 | 27.4 | 27.2 | 27.9 | 24.9 | 26.7 | 27.4 | 27.2 | 28.0 |
| 4H | 12H | 25.6 | 27.5 | 28.2 | 28.1 | 28.8 | 25.8 | 27.6 | 28.3 | 28.1 | 28.8 |
| 6H | 4H | 23.2 | 24.9 | 25.7 | 25.5 | 26.2 | 23.2 | 25.0 | 25.7 | 25.5 | 26.3 |
| 6H | 6H | 24.9 | 26.7 | 27.3 | 27.3 | 27.9 | 25.0 | 26.7 | 27.3 | 27.3 | 27.9 |
| 6H | 8H | 25.9 | 27.6 | 28.2 | 28.2 | 28.8 | 25.9 | 27.7 | 28.2 | 28.2 | 28.8 |
| 6H | 12H | 27.0 | 28.7 | 29.2 | 29.4 | 29.8 | 27.0 | 28.8 | 29.3 | 29.4 | 29.9 |
| 12H | 4H | 23.3 | 25.1 | 25.8 | 25.7 | 26.3 | 23.4 | 25.1 | 25.8 | 25.7 | 26.3 |
| 12H | 6H | 25.1 | 26.9 | 27.5 | 27.5 | 28.1 | 25.2 | 26.9 | 27.5 | 27.5 | 28.1 |
| 12H | 8H | 26.2 | 28.0 | 28.5 | 28.6 | 29.1 | 26.2 | 28.0 | 28.5 | 28.6 | 29.1 |

Variation av blickriktningar för tvärsaxeländ S

| | |
|-------------------|-------------|
| S = 1.0H | +0.1 / -0.1 |
| S = 1.5H | +0.3 / -0.3 |
| S = 2.0H | +0.4 / -0.4 |
| Standardtabell | IK11 |
| Korrektionsfaktor | 12.1 |

Kontrollerade blickriktningar relaterade till totalt ljusflöde