

## Beräkning av bländning enligt UGR

p Tak	80	70	70	50	50	80	70	70	50	50
p Vägg	60	50	30	50	30	60	50	30	50	30
p Golv	30	20	20	20	20	30	20	20	20	20

Rumsstorlek X Y		Blickriktning tvärs till tvärsaxel					Blickriktning längs till tvärsaxel				
2H	2H	-4.6	-2.8	-2.2	-2.6	-2.0	-4.6	-2.8	-2.2	-2.6	-2.0
2H	3H	-4.6	-2.7	-2.1	-2.4	-1.9	-4.6	-2.7	-2.1	-2.4	-1.9
2H	4H	-4.5	-2.6	-2.1	-2.3	-1.9	-4.5	-2.6	-2.1	-2.3	-1.9
2H	6H	-4.5	-2.7	-2.2	-2.3	-1.9	-4.5	-2.7	-2.2	-2.3	-1.9
2H	8H	-4.6	-2.7	-2.2	-2.4	-1.9	-4.6	-2.7	-2.2	-2.4	-1.9
2H	12H	-4.6	-2.7	-2.3	-2.4	-2.0	-4.6	-2.7	-2.3	-2.4	-2.0
4H	2H	-4.7	-2.8	-2.3	-2.6	-2.1	-4.7	-2.8	-2.3	-2.6	-2.1
4H	3H	-4.4	-2.5	-2.1	-2.2	-1.8	-4.4	-2.5	-2.1	-2.2	-1.8
4H	4H	-4.3	-2.4	-2.0	-2.0	-1.7	-4.3	-2.4	-2.0	-2.0	-1.7
4H	6H	-4.3	-2.4	-2.1	-2.0	-1.7	-4.3	-2.4	-2.1	-2.0	-1.7
4H	8H	-4.4	-2.4	-2.1	-2.0	-1.8	-4.4	-2.4	-2.1	-2.0	-1.8
4H	12H	-4.4	-2.5	-2.2	-2.0	-1.8	-4.4	-2.5	-2.2	-2.0	-1.8
8H	4H	-4.4	-2.4	-2.1	-2.0	-1.8	-4.4	-2.4	-2.1	-2.0	-1.8
8H	6H	-4.4	-2.4	-2.2	-2.0	-1.8	-4.4	-2.4	-2.2	-2.0	-1.8
8H	8H	-4.4	-2.5	-2.3	-2.0	-1.8	-4.4	-2.5	-2.3	-2.0	-1.8
8H	12H	-4.5	-2.5	-2.4	-2.0	-1.9	-4.5	-2.5	-2.4	-2.0	-1.9
12H	4H	-4.4	-2.5	-2.2	-2.0	-1.8	-4.4	-2.5	-2.2	-2.0	-1.8
12H	6H	-4.5	-2.5	-2.3	-2.0	-1.8	-4.5	-2.5	-2.3	-2.0	-1.8
12H	8H	-4.5	-2.5	-2.4	-2.0	-1.9	-4.5	-2.5	-2.4	-2.0	-1.9

Variation av åskådarposition för tvärsaxeländ S

S = 1.0H	+2.8 / -2.1	+2.8 / -2.1
S = 1.5H	+5.0 / -3.0	+5.0 / -3.0
S = 2.0H	+6.8 / -4.1	+6.8 / -4.1
Standardtabell Korrektionsfaktor	BK01 -20.7	BK01 -20.7

Korrigerade bländindikeringar relaterade till totalt ljusflöde