

### Beräkning av bländning enligt UGR

|             |     |                                    |      |      |      |      |                                    |      |      |      |      |
|-------------|-----|------------------------------------|------|------|------|------|------------------------------------|------|------|------|------|
| p Tak       |     | 80                                 | 70   | 70   | 50   | 50   | 80                                 | 70   | 70   | 50   | 50   |
| p Vågg      |     | 60                                 | 50   | 30   | 50   | 30   | 60                                 | 50   | 30   | 50   | 30   |
| p Golv      |     | 30                                 | 20   | 20   | 20   | 20   | 30                                 | 20   | 20   | 20   | 20   |
| Rumsstorlek |     | Blickriktning tvärs till tvärsaxel |      |      |      |      | Blickriktning längs till tvärsaxel |      |      |      |      |
| X           | Y   |                                    |      |      |      |      |                                    |      |      |      |      |
| 2H          | 2H  | 15.6                               | 17.1 | 18.3 | 17.7 | 18.9 | 16.9                               | 18.5 | 19.7 | 19.1 | 20.3 |
| 2H          | 3H  | 17.0                               | 18.6 | 19.7 | 19.2 | 20.3 | 18.9                               | 20.5 | 21.6 | 21.1 | 22.2 |
| 2H          | 4H  | 17.6                               | 19.1 | 20.2 | 19.8 | 20.8 | 19.9                               | 21.5 | 22.5 | 22.1 | 23.1 |
| 2H          | 6H  | 18.0                               | 19.5 | 20.5 | 20.2 | 21.1 | 20.8                               | 22.4 | 23.3 | 23.0 | 23.9 |
| 2H          | 8H  | 18.1                               | 19.7 | 20.6 | 20.3 | 21.2 | 21.2                               | 22.8 | 23.7 | 23.4 | 24.3 |
| 2H          | 12H | 18.2                               | 19.8 | 20.6 | 20.4 | 21.3 | 21.6                               | 23.2 | 24.1 | 23.8 | 24.7 |
| 4H          | 2H  | 16.5                               | 18.0 | 19.1 | 18.7 | 19.7 | 17.5                               | 19.1 | 20.1 | 19.7 | 20.7 |
| 4H          | 3H  | 18.1                               | 19.7 | 20.6 | 20.4 | 21.3 | 19.7                               | 21.3 | 22.2 | 22.0 | 22.8 |
| 4H          | 4H  | 18.8                               | 20.4 | 21.3 | 21.1 | 21.9 | 20.8                               | 22.4 | 23.2 | 23.1 | 23.9 |
| 4H          | 6H  | 19.4                               | 21.0 | 21.7 | 21.7 | 22.4 | 21.9                               | 23.5 | 24.2 | 24.2 | 24.9 |
| 4H          | 8H  | 19.6                               | 21.2 | 21.9 | 21.9 | 22.6 | 22.4                               | 24.0 | 24.7 | 24.7 | 25.4 |
| 4H          | 12H | 19.7                               | 21.4 | 22.0 | 22.1 | 22.7 | 22.9                               | 24.5 | 25.1 | 25.2 | 25.8 |
| 8H          | 4H  | 19.5                               | 21.1 | 21.7 | 21.8 | 22.4 | 21.1                               | 22.7 | 23.4 | 23.4 | 24.1 |
| 8H          | 6H  | 20.3                               | 21.9 | 22.5 | 22.6 | 23.2 | 22.4                               | 24.0 | 24.6 | 24.8 | 25.3 |
| 8H          | 8H  | 20.6                               | 22.3 | 22.7 | 23.0 | 23.5 | 23.1                               | 24.7 | 25.2 | 25.5 | 25.9 |
| 8H          | 12H | 20.9                               | 22.5 | 23.0 | 23.3 | 23.7 | 23.7                               | 25.4 | 25.8 | 26.1 | 26.6 |
| 12H         | 4H  | 19.6                               | 21.2 | 21.8 | 21.9 | 22.5 | 21.1                               | 22.7 | 23.4 | 23.5 | 24.1 |
| 12H         | 6H  | 20.5                               | 22.1 | 22.6 | 22.9 | 23.4 | 22.5                               | 24.1 | 24.6 | 24.9 | 25.4 |
| 12H         | 8H  | 20.9                               | 22.6 | 23.0 | 23.4 | 23.8 | 23.2                               | 24.9 | 25.3 | 25.6 | 26.1 |

### Variation av AskAdaposition för tvåsvetad S

|                   |             |             |
|-------------------|-------------|-------------|
| S = 1.0H          | +0.1 / -0.1 | +0.1 / -0.1 |
| S = 1.5H          | +0.2 / -0.3 | +0.2 / -0.2 |
| S = 2.0H          | +0.4 / -0.7 | +0.3 / -0.4 |
| Standardtabelle   | BK14        | BK09        |
| Korrektionsfaktor | 6.3         | 9.1         |

Korrigerade bländindikeringar relaterade till totalt ljusflöde