

Beräkning av bländning enligt UGR

p Tak		80	70	70	50	50	80	70	70	50	50
p Vägg		60	50	30	50	30	60	50	30	50	30
p Golv		30	20	20	20	20	30	20	20	20	20
Rumsstorlek X Y		Blickriktning tvärs till tvärsaxel					Blickriktning längs till tvärsaxel				
2H	2H	17.9	19.6	20.6	19.9	20.8	17.0	18.8	19.8	19.1	20.0
2H	3H	18.3	20.1	21.0	20.4	21.3	17.4	19.2	20.1	19.5	20.3
2H	4H	18.5	20.3	21.2	20.6	21.4	17.5	19.3	20.2	19.6	20.4
2H	6H	18.6	20.4	21.2	20.8	21.5	17.5	19.3	20.1	19.7	20.4
2H	8H	18.6	20.4	21.2	20.8	21.5	17.5	19.3	20.0	19.6	20.3
2H	12H	18.6	20.4	21.1	20.8	21.4	17.4	19.3	20.0	19.6	20.3
4H	2H	18.0	19.8	20.6	20.1	20.9	17.2	19.0	19.9	19.4	20.2
4H	3H	18.6	20.4	21.2	20.8	21.5	17.7	19.6	20.3	19.9	20.6
4H	4H	18.9	20.7	21.4	21.1	21.7	17.9	19.8	20.4	20.1	20.7
4H	6H	19.0	20.9	21.5	21.3	21.8	17.9	19.8	20.4	20.2	20.7
4H	8H	19.0	20.9	21.4	21.4	21.8	17.9	19.8	20.3	20.2	20.7
4H	12H	19.0	20.9	21.4	21.4	21.8	17.9	19.8	20.2	20.2	20.6
8H	4H	18.9	20.8	21.3	21.2	21.6	17.9	19.9	20.3	20.3	20.7
8H	6H	19.1	21.0	21.4	21.4	21.8	18.0	19.9	20.3	20.4	20.8
8H	8H	19.1	21.0	21.4	21.5	21.8	18.0	19.9	20.3	20.4	20.7
8H	12H	19.1	21.0	21.3	21.5	21.8	17.9	19.9	20.2	20.4	20.7
12H	4H	18.8	20.7	21.2	21.2	21.6	17.9	19.8	20.3	20.3	20.7
12H	6H	19.0	21.0	21.3	21.4	21.8	18.0	19.9	20.3	20.4	20.7
12H	8H	19.0	21.0	21.3	21.5	21.8	18.0	19.9	20.2	20.4	20.7
Variation av åskådarposition för tvärsnitt S											
S = 1.0H		+0.7 / -1.1					+0.9 / -1.2				
S = 1.5H		+1.9 / -1.9					+1.7 / -2.1				
S = 2.0H		+3.3 / -2.6					+3.1 / -2.9				
Standardtabell		BK02					BK02				
Korrektionsfaktor		3.0					2.0				
Korrigerade bländindikeringar relaterade till totalt ljusflöde											