

Beräkning av bländning enligt UGR

| | | | | | | | | | | |
|--------|----|----|----|----|----|----|----|----|----|----|
| p Tak | 80 | 70 | 70 | 50 | 50 | 80 | 70 | 70 | 50 | 50 |
| p Vägg | 60 | 50 | 30 | 50 | 30 | 60 | 50 | 30 | 50 | 30 |
| p Golv | 30 | 20 | 20 | 20 | 20 | 30 | 20 | 20 | 20 | 20 |

| Rumsstorlek X Y | | Blickriktning tvärs till tvärsaxel | | | | | Blickriktning längs till tvärsaxel | | | | |
|--------------------|-----|------------------------------------|------|------|------|------|------------------------------------|------|------|------|------|
| 2H | 2H | 10.4 | 11.8 | 12.4 | 12.9 | 13.4 | 9.0 | 10.5 | 11.0 | 11.5 | 12.0 |
| 2H | 3H | 10.1 | 11.5 | 12.0 | 12.6 | 13.1 | 8.8 | 10.2 | 10.7 | 11.2 | 11.7 |
| 2H | 4H | 10.0 | 11.4 | 11.8 | 12.4 | 12.9 | 8.6 | 10.0 | 10.5 | 11.1 | 11.5 |
| 2H | 6H | 9.9 | 11.2 | 11.7 | 12.3 | 12.7 | 8.5 | 9.9 | 10.3 | 11.0 | 11.4 |
| 2H | 8H | 9.8 | 11.2 | 11.6 | 12.3 | 12.6 | 8.4 | 9.8 | 10.2 | 10.9 | 11.3 |
| 2H | 12H | 9.7 | 11.1 | 11.5 | 12.2 | 12.5 | 8.4 | 9.8 | 10.1 | 10.9 | 11.2 |
| 4H | 2H | 10.0 | 11.4 | 11.8 | 12.4 | 12.9 | 8.6 | 10.0 | 10.5 | 11.1 | 11.5 |
| 4H | 3H | 9.7 | 11.1 | 11.4 | 12.2 | 12.5 | 8.3 | 9.7 | 10.1 | 10.8 | 11.2 |
| 4H | 4H | 9.5 | 10.9 | 11.2 | 12.0 | 12.3 | 8.2 | 9.6 | 9.9 | 10.7 | 11.0 |
| 4H | 6H | 9.4 | 10.8 | 11.0 | 11.9 | 12.1 | 8.1 | 9.4 | 9.7 | 10.6 | 10.8 |
| 4H | 8H | 9.3 | 10.7 | 10.9 | 11.8 | 12.1 | 8.0 | 9.4 | 9.6 | 10.5 | 10.7 |
| 4H | 12H | 9.3 | 10.6 | 10.9 | 11.8 | 12.0 | 8.0 | 9.3 | 9.6 | 10.5 | 10.7 |
| 8H | 4H | 9.3 | 10.7 | 10.9 | 11.8 | 12.0 | 8.0 | 9.3 | 9.6 | 10.4 | 10.7 |
| 8H | 6H | 9.2 | 10.5 | 10.7 | 11.7 | 11.8 | 7.8 | 9.2 | 9.4 | 10.3 | 10.5 |
| 8H | 8H | 9.1 | 10.5 | 10.6 | 11.6 | 11.8 | 7.8 | 9.1 | 9.3 | 10.3 | 10.5 |
| 8H | 12H | 9.1 | 10.4 | 10.6 | 11.6 | 11.7 | 7.8 | 9.1 | 9.3 | 10.3 | 10.4 |
| 12H | 4H | 9.2 | 10.6 | 10.8 | 11.7 | 11.9 | 7.9 | 9.2 | 9.5 | 10.4 | 10.6 |
| 12H | 6H | 9.1 | 10.4 | 10.6 | 11.6 | 11.7 | 7.8 | 9.1 | 9.3 | 10.3 | 10.4 |
| 12H | 8H | 9.0 | 10.4 | 10.5 | 11.5 | 11.7 | 7.7 | 9.1 | 9.2 | 10.2 | 10.4 |

Variation av åskådarposition för tvärsaxeländ S

| | | |
|-------------------|--------------|--------------|
| S = 1.0H | +4.9 / -10.4 | +4.0 / -8.9 |
| S = 1.5H | +7.6 / -10.9 | +6.7 / -9.7 |
| S = 2.0H | +9.6 / -11.5 | +8.7 / -10.2 |
| Standardtabell | BK00 | BK00 |
| Korrektionsfaktor | -5.4 | -6.7 |

Korrigerade bländindikeringar relaterade till totalt ljusflöde