

Beräkning av bländning enligt UGR

| | | | | | | | | | | |
|--------|----|----|----|----|----|----|----|----|----|----|
| p Tak | 80 | 70 | 70 | 50 | 50 | 80 | 70 | 70 | 50 | 50 |
| p Vägg | 60 | 50 | 30 | 50 | 30 | 60 | 50 | 30 | 50 | 30 |
| p Golv | 30 | 20 | 20 | 20 | 20 | 30 | 20 | 20 | 20 | 20 |

| Rumsstorlek X Y | | Blickriktning tvärs till tvärsaxel | | | | | Blickriktning längs till tvärsaxel | | | | |
|--------------------|-----|------------------------------------|-----|------|------|------|------------------------------------|-----|-----|-----|-----|
| 2H | 2H | 8.0 | 9.4 | 10.0 | 10.5 | 11.0 | 6.8 | 8.2 | 8.7 | 9.2 | 9.8 |
| 2H | 3H | 7.8 | 9.2 | 9.7 | 10.3 | 10.7 | 6.5 | 7.9 | 8.4 | 9.0 | 9.5 |
| 2H | 4H | 7.7 | 9.0 | 9.5 | 10.2 | 10.6 | 6.4 | 7.8 | 8.2 | 8.9 | 9.3 |
| 2H | 6H | 7.6 | 8.9 | 9.4 | 10.1 | 10.4 | 6.4 | 7.7 | 8.1 | 8.9 | 9.2 |
| 2H | 8H | 7.6 | 8.9 | 9.3 | 10.0 | 10.4 | 6.4 | 7.8 | 8.2 | 8.9 | 9.3 |
| 2H | 12H | 7.6 | 8.9 | 9.3 | 10.1 | 10.4 | 6.5 | 7.9 | 8.2 | 9.0 | 9.3 |
| 4H | 2H | 7.6 | 9.0 | 9.4 | 10.1 | 10.5 | 6.4 | 7.7 | 8.2 | 8.8 | 9.3 |
| 4H | 3H | 7.4 | 8.7 | 9.1 | 9.8 | 10.2 | 6.1 | 7.5 | 7.8 | 8.6 | 8.9 |
| 4H | 4H | 7.3 | 8.6 | 8.9 | 9.7 | 10.0 | 6.0 | 7.4 | 7.7 | 8.5 | 8.8 |
| 4H | 6H | 7.2 | 8.5 | 8.8 | 9.7 | 10.0 | 6.1 | 7.4 | 7.7 | 8.6 | 8.8 |
| 4H | 8H | 7.2 | 8.5 | 8.8 | 9.7 | 9.9 | 6.2 | 7.5 | 7.8 | 8.7 | 8.9 |
| 4H | 12H | 7.3 | 8.6 | 8.9 | 9.8 | 10.0 | 6.4 | 7.7 | 8.0 | 8.9 | 9.1 |
| 8H | 4H | 7.0 | 8.4 | 8.6 | 9.5 | 9.8 | 5.9 | 7.2 | 7.4 | 8.3 | 8.6 |
| 8H | 6H | 7.1 | 8.4 | 8.6 | 9.6 | 9.7 | 5.9 | 7.3 | 7.5 | 8.4 | 8.6 |
| 8H | 8H | 7.1 | 8.4 | 8.6 | 9.6 | 9.8 | 6.2 | 7.5 | 7.7 | 8.7 | 8.8 |
| 8H | 12H | 7.3 | 8.7 | 8.8 | 9.8 | 10.0 | 6.6 | 7.9 | 8.1 | 9.1 | 9.2 |
| 12H | 4H | 7.0 | 8.3 | 8.5 | 9.5 | 9.7 | 5.8 | 7.1 | 7.3 | 8.3 | 8.5 |
| 12H | 6H | 7.0 | 8.3 | 8.5 | 9.5 | 9.7 | 5.9 | 7.2 | 7.4 | 8.4 | 8.6 |
| 12H | 8H | 7.1 | 8.4 | 8.6 | 9.6 | 9.7 | 6.2 | 7.5 | 7.7 | 8.7 | 8.8 |

Variation av åskådarposition för tvärsavstånd S

| | | |
|----------|-------------|-------------|
| S = 1.0H | +4.2 / -5.3 | +3.3 / -3.8 |
| S = 1.5H | +6.9 / -5.9 | +5.6 / -4.3 |
| S = 2.0H | +9.0 / -6.3 | +7.6 / -4.9 |

| | | |
|-------------------|------|------|
| Standardtabell | BK01 | BK01 |
| Korrektionsfaktor | -7.2 | -8.2 |

Korrigerade bländindikeringar relaterade till totalt ljusflöde