

Beräkning av blandning enligt UGR

| ρ Tak | 60 | 70 | 70 | 50 | 50 | 60 | 70 | 70 | 50 | 50 | |
|------------------|-----|------------------------------------|------|------|------|------|------------------------------------|------|------|------|------|
| ρ Vågg | 60 | 50 | 30 | 50 | 30 | 60 | 50 | 30 | 50 | 30 | |
| ρ Golv | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | |
| Rumsstorlek X | Y | Blickriktning tvärs till tvärsaxel | | | | | Blickriktning längs till tvärsaxel | | | | |
| 2H | 2H | 21.1 | 22.8 | 23.9 | 23.1 | 24.2 | 21.4 | 23.1 | 24.2 | 23.4 | 24.5 |
| 2H | 3H | 21.4 | 23.1 | 24.1 | 23.5 | 24.4 | 21.9 | 23.7 | 24.6 | 24.0 | 24.9 |
| 2H | 4H | 21.4 | 23.2 | 24.1 | 23.5 | 24.4 | 22.1 | 23.8 | 24.8 | 24.2 | 25.1 |
| 2H | 6H | 21.3 | 23.1 | 24.0 | 23.5 | 24.3 | 22.1 | 23.9 | 24.8 | 24.3 | 25.1 |
| 2H | 8H | 21.3 | 23.1 | 23.9 | 23.5 | 24.2 | 22.1 | 23.9 | 24.8 | 24.3 | 25.1 |
| 2H | 12H | 21.2 | 23.1 | 23.8 | 23.4 | 24.2 | 22.1 | 23.9 | 24.7 | 24.3 | 25.0 |
| 4H | 2H | 21.2 | 23.0 | 23.9 | 23.3 | 24.2 | 21.5 | 23.3 | 24.2 | 23.7 | 24.9 |
| 4H | 3H | 21.6 | 23.4 | 24.2 | 23.8 | 24.5 | 22.1 | 23.9 | 24.7 | 24.3 | 25.0 |
| 4H | 4H | 21.6 | 23.5 | 24.1 | 23.9 | 24.5 | 22.3 | 24.2 | 24.9 | 24.6 | 25.2 |
| 4H | 6H | 21.6 | 23.4 | 24.0 | 23.9 | 24.4 | 22.8 | 24.3 | 24.9 | 24.8 | 25.3 |
| 4H | 8H | 21.6 | 23.4 | 24.0 | 23.9 | 24.4 | 22.5 | 24.4 | 24.9 | 24.8 | 25.3 |
| 4H | 12H | 21.5 | 23.4 | 23.9 | 23.9 | 24.3 | 22.5 | 24.3 | 24.8 | 24.8 | 25.3 |
| 6H | 4H | 21.6 | 23.5 | 24.0 | 23.9 | 24.4 | 22.3 | 24.1 | 24.7 | 24.6 | 25.1 |
| 6H | 6H | 21.6 | 23.5 | 23.9 | 23.9 | 24.4 | 22.4 | 24.3 | 24.8 | 24.8 | 25.2 |
| 6H | 8H | 21.5 | 23.4 | 23.8 | 23.9 | 24.3 | 22.8 | 24.4 | 24.7 | 24.9 | 25.3 |
| 6H | 12H | 21.5 | 23.4 | 23.7 | 23.9 | 24.2 | 22.4 | 24.4 | 24.7 | 24.9 | 25.2 |
| 12H | 4H | 21.6 | 23.4 | 23.9 | 23.9 | 24.4 | 22.2 | 24.1 | 24.6 | 24.6 | 25.0 |
| 12H | 6H | 21.5 | 23.4 | 23.8 | 23.9 | 24.3 | 22.4 | 24.3 | 24.7 | 24.8 | 25.1 |
| 12H | 8H | 21.5 | 23.4 | 23.7 | 23.9 | 24.2 | 22.4 | 24.3 | 24.7 | 24.8 | 25.1 |

Variation av blickriktning för tvärsaxel S

| | | |
|-------------------|-------------|-------------|
| S = 1.0H | +0.7 / -1.2 | +0.8 / -0.7 |
| S = 1.5H | +1.5 / -2.2 | +1.4 / -1.5 |
| S = 2.0H | +3.0 / -3.7 | +2.7 / -2.8 |
| Standardavb.: | 0.01 | 0.02 |
| Korrektionsfaktor | 5.4 | 6.6 |

Kontrollerade blickriktning för relativt till totalt ljusflöde